

## System 636<sup>®</sup> Access Tee

Periodic flue gas monitoring is a fast growing requirement for many gas-fired heating appliances.

It is common today to conduct such monitoring by inserting special electronic probes into the vent line during actual operation. Drilling small holes into the vent line and plugging afterwards is no longer a permitted practice.

To help address this field issue, IPEX offers the Molded Access Tee to allow an inline access point for flue monitoring using fully certified System 636<sup>®</sup> components. The kit is available in both PVC and CPVC.

Size Inches	PVC Product Code	CPVC Product Code
1-1/2	196510	-
2	196511	197511
3	196512	197512
4	196513	197513



### Features and Benefits:

- May be installed in new installations or added to existing lines when monitoring is required
- Replaces current IPEX Testing Plug and Bushing Kit and includes new product codes
- May be used on vent lines in diameters (1-1/2" – 4")
- Certified for use only on IPEX System 636 flue gas vent lines
- Molded tee design with IPEX System 636 removable 1/2" MPT plug
- More compact and robust design

### Standards:



### Contact us

Visit our website: [ipexna.com](http://ipexna.com)

Toll free Canada: (866) 473-9462

System 636<sup>®</sup> is a registered trademark.