

PVC Bell End Conduit in 10' and 20' Lengths (Sch 40 & Sch 80)




Below are critical dimensions of Scepter PVC Schedule 40 and 80 Conduit made by IPEX USA. All pipe* is certified to UL 651 and NEMA TC 2.

*Size 8" has pending UL 651 certification

APPLICATIONS / USE

- Utilities
- Parking garages
- Cable
- Car washes
- Communications
- Fish plants
- Residential
- Mines
- Airports
- Marinas
- Subways
- Steel mills
- Bridges & tunnels
- Water treatment plants
- Sewage treatment plants
- Pulp & paper industries
- Street & highway lighting
- Food processing plants
- Agricultural, dairy, hogs, cattle, chicken, etc.



Schedule 40 PVC Conduit Heavy Wall

Pipe Size	L 10' Product Code	L 20' Product Code	OD	t (min)	ID	C (min)
1/2	032405	032406	0.84	0.11	0.62	1.38
3/4	032407	032408	1.05	0.11	0.82	1.38
1	032410	032411	1.31	0.13	1.05	1.57
1-1/4	032056	032414	1.66	0.14	1.38	1.77
1-1/2	032415	032416	1.90	0.14	1.61	2.01
2	032420	032421	2.37	0.15	2.07	2.28
2-1/2	032425	032426	2.88	0.20	2.47	2.76
3	032430	032431	3.50	0.22	3.07	3.27
3-1/2	032435	032436	4.00	0.23	3.55	3.27
4	032440	032441	4.50	0.24	4.03	4.02
5	032450	032451	5.56	0.26	5.05	5.00
6	032460	032461	6.63	0.28	6.07	6.02
8*	032180	032181	8.63	0.32	7.98	6.00

Schedule 80 PVC Conduit Extra Heavy Wall

Pipe Size	L 10' Product Code	L 20' Product Code	OD	t (min)	ID	C (min)
1/2	032505	032506	0.84	0.15	0.55	1.38
3/4	032507	032508	1.05	0.15	0.72	1.38
1	032510	032511	1.31	0.18	0.96	1.57
1-1/4	032512	032514	1.66	0.19	1.28	1.77
1-1/2	032515	032516	1.90	0.20	1.50	2.01
2	032520	032521	2.37	0.22	1.94	2.28
2-1/2	032525	032526	2.88	0.28	2.32	2.76
3	032530	032531	3.50	0.30	2.90	3.27
3-1/2	-	-	-	-	-	-
4	032540	032541	4.50	0.34	3.83	4.02
5	032550	032551	5.56	0.37	4.81	5.00
6	032560	032561	6.63	0.43	5.76	6.02
8	-	-	-	-	-	-

All dimensions are in inches unless otherwise indicated.



IPEX
by aliaxis